

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI009960-R4  
DATE: 07/01/2009  
CERTIFICATION PROGRAM: Structural  
COMPANY: Eagan  
CODE: 1537-1  
REVISION DATE: 11/02/2021

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Eagan Manufacturing, Inc.</b> <b>602 Eagan Road</b> <b>Black Rock, AR 72415</b>	<b>Series "Aluminum Single Non-Hung Window"</b>  Configuration: O/X  Glazing: Monolithic (Annealed Glass)  Frame: W-965mm(38") H-965mm(38") Sash: W-902mm(35.5") H-457mm(18")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-05</b>	<b>VS-R20 965 x 965 (38 x 38)</b>

Product Tested By: Certified Testing Laboratories  
Report No: CTLA-1980W-5R/CTLA-1960W-6  
Expiration Date: **July 31, 2032**

A handwritten signature in black ink, appearing to be 'S. D.', written over a horizontal line.

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122